



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J0C1438

**Sherburne-Earlville CSD**

**Project Name: Lead in schools**

Fred Wright  
 15 School Street  
 Sherburne, NY 13460

Project / PO Number: 012399  
 Received: 03/25/2020  
 Reported: 04/14/2020

**Analytical Testing Parameters**

<b>Client Sample ID:</b>	SCS 1 = Sink - Stadium Concession Stand	<b>Collected By:</b>	JG-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	03/19/2020 8:00
<b>Lab Sample ID:</b>	J0C1438-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0014	0.015 AL	0.0010	mg/L		04/02/20 1139	04/02/20 1501	DLO

<b>Client Sample ID:</b>	SCS DF = Drinking Fntain - Exterior Stadium	<b>Collected By:</b>	JG-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	03/19/2020 8:05
<b>Lab Sample ID:</b>	J0C1438-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/20 1139	04/02/20 1503	DLO

<b>Client Sample ID:</b>	BG O-1 = Sink - Transportation Break Rm	<b>Collected By:</b>	JG-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	03/19/2020 8:35
<b>Lab Sample ID:</b>	J0C1438-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/20 1139	04/02/20 1505	DLO

<b>Client Sample ID:</b>	BG WBDF = Drinking Fntain - Trans. Break Rm	<b>Collected By:</b>	JG-Client
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	03/19/2020 8:30
<b>Lab Sample ID:</b>	J0C1438-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/20 1139	04/02/20 1511	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1438

<b>Client Sample ID:</b> GCS 1 = Sink - Granville Concession Stand	<b>Collected By:</b> JG-Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/19/2020 8:30
<b>Lab Sample ID:</b> J0C1438-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		04/02/20 1139	04/02/20 1512	DLO

<b>Client Sample ID:</b> GCS DF = Drinking Fntain - Exterior Granville	<b>Collected By:</b> JG-Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/19/2020 8:35
<b>Lab Sample ID:</b> J0C1438-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/20 1139	04/02/20 1514	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- MCL:** US EPA Maximum Contaminant Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville  
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks  
Customer Relationship Coordinator  
Reported: 04/14/2020 16:40

