



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0C1439

Sherburne-Earlville CSD

Project Name: Lead in schools

Fred Wright
 15 School Street
 Sherburne, NY 13460

Project / PO Number: 012399
 Received: 03/25/2020
 Reported: 04/20/2020

Analytical Testing Parameters

Client Sample ID:	HSDF1 = Drinking Fntain - Hall Behind Stage	Collected By:	JG-Client
Sample Matrix:	Drinking Water	Collection Date:	03/19/2020 7:24
Lab Sample ID:	J0C1439-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1419	DLO

Client Sample ID:	HS236 = Hand Sink - Band Rm Office	Collected By:	JG-Client
Sample Matrix:	Drinking Water	Collection Date:	03/19/2020 7:27
Lab Sample ID:	J0C1439-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0067	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1425	DLO

Client Sample ID:	HS236DF = Drinking Fntain - Band Rm	Collected By:	JG-Client
Sample Matrix:	Drinking Water	Collection Date:	03/19/2020 7:28
Lab Sample ID:	J0C1439-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1426	DLO

Client Sample ID:	HSDF2 = Drinking Fntain - Rm 234	Collected By:	JG-Client
Sample Matrix:	Drinking Water	Collection Date:	03/19/2020 7:30
Lab Sample ID:	J0C1439-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1428	DLO

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HS OT/PT = Wash Sink - OT/PT Rm	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:33
Lab Sample ID: J0C1439-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1430	DLO

Client Sample ID: HSDF3 = Drinking Fntain - Auditorium Lobby	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:34
Lab Sample ID: J0C1439-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1432	DLO

Client Sample ID: HS227 = Wash Sink	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:37
Lab Sample ID: J0C1439-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0083	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1437	DLO

Client Sample ID: HS228 = Hand Sink - Computer Bread Rm	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:39
Lab Sample ID: J0C1439-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0141	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1439	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HS226 1 = Wash Sink	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:41
Lab Sample ID: J0C1439-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1441	DLO

Client Sample ID: HS226 2 = Wash Sink	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:41
Lab Sample ID: J0C1439-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1443	DLO

Client Sample ID: HS226 3 = Wash Sink	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:42
Lab Sample ID: J0C1439-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1445	DLO

Client Sample ID: HS226 4 = Wash Sink	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:42
Lab Sample ID: J0C1439-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1448	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HS226 5 = Wash Sink	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:43
Lab Sample ID: J0C1439-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1451	DLO

Client Sample ID: HS226 6 = Wash Sink	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:44
Lab Sample ID: J0C1439-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1501	DLO

Client Sample ID: HS226 7 = Wash Sink	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:44
Lab Sample ID: J0C1439-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0050	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1503	DLO

Client Sample ID: HS MSOFF = Kitchen Sink - Break Rm	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:46
Lab Sample ID: J0C1439-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1509	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSDF4 = Drinking Fntain - X from Faculty Rstrms	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:48
Lab Sample ID: J0C1439-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1510	DLO

Client Sample ID: HSDF5 = Drinking Fntain - Next to BGO	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:50
Lab Sample ID: J0C1439-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1512	DLO

Client Sample ID: HSK1 = Hand Sink - Kitchen Serving Area	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:53
Lab Sample ID: J0C1439-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1514	DLO

Client Sample ID: HSK2 = Prep Sink - Kitchen	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:54
Lab Sample ID: J0C1439-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.015 AL	0.0010	mg/L		04/14/20 1406	04/14/20 1516	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSDf6 = Drinking Fntain - Out Rstrm 12	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:57
Lab Sample ID: J0C1439-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1525	DLO

Client Sample ID: HSDf7 = Drinking Fntain - Out Rstrm 13 high	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:58
Lab Sample ID: J0C1439-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1531	DLO

Client Sample ID: HSDf8 = Drinking Fntain - Out Rstrm 13 low	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 7:59
Lab Sample ID: J0C1439-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1532	DLO

Client Sample ID: HSDf9 = Drinking Fntain - By Rm 126	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:02
Lab Sample ID: J0C1439-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1534	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSLWR1 = Hand Sink - Work Rm 1 Library	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:04
Lab Sample ID: J0C1439-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1536	DLO

Client Sample ID: HSDF10 = drinking Fntain - X from Bassett	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:06
Lab Sample ID: J0C1439-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1538	DLO

Client Sample ID: HSBASS1 = Hand Sink - Bassett Rm 1	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:07
Lab Sample ID: J0C1439-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1543	DLO

Client Sample ID: HSBASS2 = Hand Sink - Bassett Rm 2	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:08
Lab Sample ID: J0C1439-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1545	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSBASS3 = Hand Sink - Bassett Rm 3	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:09
Lab Sample ID: J0C1439-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1547	DLO

Client Sample ID: HSFAC = Hand Sink - HS Faculty Rm Countner	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:11
Lab Sample ID: J0C1439-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1549	DLO

Client Sample ID: HSDF11 = Drinking Fntain - By Bookrm 1	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:13
Lab Sample ID: J0C1439-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1551	DLO

Client Sample ID: HSDF12 = Drinking Fntain - X from Rm 120	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:15
Lab Sample ID: J0C1439-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1554	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSNM = Hand Sink - Nursing Mother's Rm	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:17
Lab Sample ID: J0C1439-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1556	DLO

Client Sample ID: HSN 1 = Hand Sink - Back Counter twrds Bassett	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:21
Lab Sample ID: J0C1439-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1558	DLO

Client Sample ID: HSN 2 = Hand Sink - Back Counter twrds N's Off.	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:22
Lab Sample ID: J0C1439-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1600	DLO

Client Sample ID: HSGOC = Hand Sink - HS Counselor Conf Rm	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:25
Lab Sample ID: J0C1439-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1605	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSDF13 = Drinking Fntain - X from Rm 158	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:27
Lab Sample ID: J0C1439-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1607	DLO

Client Sample ID: HS160 = Wash Sink - Rm 160	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:28
Lab Sample ID: J0C1439-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1609	DLO

Client Sample ID: HSDF17 = Drinking Fntain - MS Girl Lckr Rm	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:31
Lab Sample ID: J0C1439-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1611	DLO

Client Sample ID: HSDF14A = Drinking Fntain - MS Gym Fyr High	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:37
Lab Sample ID: J0C1439-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1407	04/14/20 1613	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSDF14B = Drinking Fntain - MS Gym Fyr Low	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:33
Lab Sample ID: J0C1439-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1622	DLO

Client Sample ID: HST/C = Hand Sink - HS Trnng/Concession Stand	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:37
Lab Sample ID: J0C1439-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1627	DLO

Client Sample ID: HSDF15 = Drinking Fntain - By Coat Off. High	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:39
Lab Sample ID: J0C1439-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1629	DLO

Client Sample ID: HSDF16 = Drinking Fntain - By Coach Off. Low	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:39
Lab Sample ID: J0C1439-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1631	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSDF18 = Drinking Fntain - Boy Lckr Rm, Trnng	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:41
Lab Sample ID: J0C1439-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1633	DLO

Client Sample ID: HSDF18A = Drinking Fntain - X 1st Set Gym Drs	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:43
Lab Sample ID: J0C1439-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1635	DLO

Client Sample ID: HSDF19 = Drinking Fntain - X 2nd Set Gym Drs	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:45
Lab Sample ID: J0C1439-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1640	DLO

Client Sample ID: HSDF20 = Drinkingn Fntain - Girl Locker Rm	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:46
Lab Sample ID: J0C1439-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1642	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HSDF21 = Drinking Fntain - Pool	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:47
Lab Sample ID: J0C1439-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1644	DLO

Client Sample ID: HSWRDF22 = Drinking Fntain - Weight Rm	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 8:49
Lab Sample ID: J0C1439-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1646	DLO

Client Sample ID: HSIMK = Ice Machine - Kitchen	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/18/2020 15:00
Lab Sample ID: J0C1439-51	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1648	DLO

Client Sample ID: HSIMCS = Ice Machine - Concession Stand	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/18/2020 15:00
Lab Sample ID: J0C1439-52	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1651	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1439

Client Sample ID: HS225	Collected By: JG-Client
Sample Matrix: Drinking Water	Collection Date: 03/19/2020 9:30
Lab Sample ID: J0C1439-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.015 AL	0.0010	mg/L		04/14/20 1445	04/14/20 1653	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- MCL:** US EPA Maximum Contaminant Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.


Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 04/20/2020 12:22

Client Information		Billing/Invoice:	
Name:	Sherburne-Earlville CSD		
Address:	13-15 School Street		
Contact:	Sherburne, New York 13460		
Phone:	Jeffrey Genter		
Project:	607-674-7329		
Quote ID:	Lead Testing	PO#	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		

Sample Information				Matrix	
Description/Location	Initials	Date	Time	Type	
1 HSDF1 = Drinking Fntain - Hall Behind Stage	J.G.	3/19/2020	7:24 AM	DW	
2 HS236 = Hand Sink - Band Rm Office	J.G.	3/19/2020	7:27 AM	DW	
3 HS236DF = Drinking Fntain - Band Rm	J.G.	3/19/2020	7:28 AM	DW	
4 HSDF2 = Drinking Fntain - Rm 234	J.G.	3/19/2020	7:30 AM	DW	
5 HS OT/PT = Wash Sink - OT/PT Rm	J.G.	3/19/2020	7:33 AM	DW	
6 HSDF3 = Drinking Fntain - Auditorium Lobby	J.G.	3/19/2020	7:34 AM	DW	
7 HS227 = Wash Sink	J.G.	3/19/2020	7:37 AM	DW	
8 HS228 = Hand Sink - Computer Bread Rm	J.G.	3/19/2020	7:39 AM	DW	
9 HS226 1 = Wash Sink	J.G.	3/19/2020	7:41 AM	DW	
10 HS226 2 = Wash Sink	J.G.	3/19/2020	7:41 AM	DW	
11 HS226 3 = Wash Sink	J.G.	3/19/2020	7:42 AM	DW	
12 HS226 4 = Wash Sink	J.G.	3/19/2020	7:42 AM	DW	
13 HS226 5 = Wash Sink	J.G.	3/19/2020	7:43 AM	DW	
14 HS226 6 = Wash Sink	J.G.	3/19/2020	7:44 AM	DW	
15 HS226 7 = Wash Sink	J.G.	3/19/2020	7:44 AM	DW	
16 HS MSOFF = Kitchen Sink - Break Rm	J.G.	3/19/2020	7:46 AM	DW	
17 HSDF4 = Drinking Fntain - X from Faculty Rstrms	J.G.	3/19/2020	7:48 AM	DW	
18 HSDF5 = Drinking Fntain - Next to BGO	J.G.	3/19/2020	7:50 AM	DW	
19 HSK1 = Hand Sink - Kitchen Serving Area	J.G.	3/19/2020	7:53 AM	DW	
20 HSK2 = Prep Sink - Kitchen	J.G.	3/19/2020	7:54 AM	DW	

Receiving Info (Lab Use Only)		Analysis Requested		Comments/Field Data	
Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				
Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				
Sample Temp:	20.5				
Cooler seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>				
Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>				
Dropoff:	C W				
Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				
Container Material					
Container size(in MI)					
Preservative	None				



J 0 C 1 4 3 9
 Sherburne-Earlville CSD
 PM: Shannon Weeks

Print Name and Company		Date/Time	Comments
Sampled:	Jeffrey Genter	3/24/20	
Received:	Jennifer Walker	3/25/2020	9:35
Received:	Microbac		

Client Information		Billing/Invoices:	
Name:	Sherburne-Earlville CSD		
Address:	13-15 School Street Sherburne, New York 13460		
Contact:	Jeffrey Genter		
Phone:	607-674-7329		
Project:			
Quote ID:	Lead Testing	PO#	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		

Sample Information				Matrix	
Description/Location	Initials	Date	Time	Type	
1 HSDf6 = Drinking Fountain - Out Rstrm 12	J.G.	3/19/2020	7:57 AM	DW	
2 HSDf7 = Drinking Fountain - Out Rstrm 13 high	J.G.	3/19/2020	7:58 AM	DW	
3 HSDf8 = Drinking Fountain - Out Rstrm 13 low	J.G.	3/19/2020	7:59 AM	DW	
4 HSDf9 = Drinking Fountain - By Rm 126	J.G.	3/19/2020	8:02 AM	DW	
5 HSLWR1 = Hand Sink - Work Rm 1 Library	J.G.	3/19/2020	8:04 AM	DW	
6 HSDf10 = Drinking Fountain - X from Bassett	J.G.	3/19/2020	8:06 AM	DW	
7 HSBASS1 = Hand Sink - Bassett Rm 1	J.G.	3/19/2020	8:07 AM	DW	
8 HSBASS2 = Hand Sink - Bassett Rm 2	J.G.	3/19/2020	8:08 AM	DW	
9 HSBASS3 = Hand Sink - Bassett Rm 3	J.G.	3/19/2020	8:09 AM	DW	
10 HSFAC = Hand Sink - HS Faculty Rm Counter	J.G.	3/19/2020	8:11 AM	DW	
11 HSDf11 = Drinking Fountain - By Bookrm 1	J.G.	3/19/2020	8:13 AM	DW	
12 HSDf12 = Drinking Fountain - X from Rm 120	J.G.	3/19/2020	8:15 AM	DW	
13 HSNM = Hand Sink - Nursing Mother's Rm	J.G.	3/19/2020	8:17 AM	DW	
14 HSN 1 = Hand Sink - Back Counter twrds Bassett	J.G.	3/19/2020	8:21 AM	DW	
15 HSN 2 = Hand Sink - Back Counter twrds N's Off.	J.G.	3/19/2020	8:22 AM	DW	
16 HSGOC = Hand Sink - HS Counselor Conf Rm	J.G.	3/19/2020	8:25 AM	DW	
17 HSDf13 = Drinking Fountain - X from Rm 158	J.G.	3/19/2020	8:27 AM	DW	
18 HSI160 = Wash Sink - Rm 160	J.G.	3/19/2020	8:28 AM	DW	
19 HSDf17 = Drinking Fountain - MS Girl Lechr Rm	J.G.	3/19/2020	8:31 AM	DW	
20 HSDf14A = Drinking Fountain - MS Gym Fyr High	J.G.	3/19/2020	8:37 AM	DW	

Receiving Info (Lab Use Only)		Analysis Requested		Number of Containers for Analysis Requested		Comments/Field Data	
Ice:	YES NO						
Cooler:	YES NO						
Sample Temp:							
Cooler Seal:	YES NO						
Pickup:	YES NO						
Dropoff:	C W						
Accepted?	YES NO						
Container Material							
Container Size(in MI)							
Preservative	None						

Print Name and Company	Date/Time	Comments
Jeffrey Genter SECS	3/24/20	
Jennifer Walker Microbac	3/25/2020 9:35	

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on
 MNY Workorder # _____

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Sherburne-Earville CSD					Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Address:	13-15 School Street					Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Contact:	Sherburne, New York 13460					Sample Temp:	20.5
Phone:	Jeffrey Genter					Cooler Seal:	YES NO
Project:	607-674-7329					Pickup:	YES NO
Quote ID:	Lead Testing	PO#				Dropoff:	C W
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:				Accepted?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Carbon Copy:	Yes					Container Material	
Email Results:	Yes					Container Size (in MI)	
Fax Results:	Yes					Preservative	None

Sample Information				Matrix		Number of Containers for Analysis Requested	Comments/Field Data
Description/Location	Initials	Date	Time	Type			
1 HSD14B = Drinking Fountain - MS Gym Fyr Low	J.G.	3/19/2020	8:33 AM	DW	1		
2 HST/C = Hand Sink - HS Trnng/Concession Stand	J.G.	3/19/2020	8:37 AM	DW	1		
3 HSD15 = Drinking Fountain - By Coach Off. High	J.G.	3/19/2020	8:39 AM	DW	1		
4 HSD16 = Drinking Fountain - By Coach Off. Low	J.G.	3/19/2020	8:39 AM	DW	1		
5 HSD18 = Drinking Fountain - Boy Lckr Rm, Trnng	J.G.	3/19/2020	8:41 AM	DW	1		
6 HSD18A = Drinking Fountain - X 1st Set Gym Drs	J.G.	3/19/2020	8:43 AM	DW	1		
7 HSD19 = Drinking Fountain - X 2nd Set Gym Drs	J.G.	3/19/2020	8:45 AM	DW	1		
8 HSD20 = Drinking Fountain - Girl Locker Rm	J.G.	3/19/2020	8:46 AM	DW	1		
9 HSD21 = Drinking Fountain - Pool	J.G.	3/19/2020	8:47 AM	DW	1		
10 HSWRDF22 = Drinking Fountain - Weight Rm	J.G.	3/19/2020	8:49 AM	DW	1		
11 HSMK = Ice Machine - Kitchen	J.G.	3/18/2020	3:00 PM	DW	1		
12 HSMCS = Ice Machine - Concession Stand	J.G.	3/18/2020	3:00 PM	DW	1		
13							
14							
15							
16							
17							
18							
19							
20							

Sampled:	Received:	Print Name and Company	Date/Time	Comments
Jeffrey Genter	Jennifer Walker	Microbac	3/24/20	
			3/25/2020 9:35	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.